



PROGRESS IN MOTION

CITY OF FRISCO PURCHASING DIVISION

February 17, 2012

Addendum #1

Bid # 1201-038

Community Park Pump & Mainline Installation

Questions & Answers from the Mandatory Pre-Bid Meeting of 2/15/2012

Change in Opening Date from February 23, 2012 at 2:00PM to March 1, 2012 at 2:00PM CST

Site Visit Requirements for Contractors who did not attend the Mandatory Pre Bid Meeting on February 15, 2012.

Question:

Plans call for a PVC Saddle – Do you want Steel Saddle?

Answer:

Yes. We want Steel Saddle

Question:

Do you want an isolation valve at each mainline connection?

Answer:

A manual isolation valve shall be provided and installed by the contractor at each point of connection to existing mainline as shown on the plans. Isolation valves shall be the same size as the mainline pipe. Size 3" and smaller shall be sch. 80 pvc ball valves as manufactured by Spears or equal. Size 4" and larger shall be cast iron push-on type gate valves as manufactured by Kennedy or equal. All valves shall be installed in a 12" x 17" valve box set flush with grade"

Opening Date:

The Opening Date has been pushed out to March 1, 2012 at 2:00PM CST. Bid will be opened in Conference Room C116 at the City of Frisco City Hall, 6101 Frisco Sq. Blvd., Frisco, TX 75034.

Site Visit Deadline is February 23, 2012 prior to the new Opening Date of March 1, 2012 at 2:00PM CST. Site Visit requirements are as follows below:

Contractors who **did not** attend the Mandatory Pre-Bid meeting on February 15, 2012 at 1:00PM CST must visit/tour each site prior to submitting their bids. Wes Hicks, Parks Project Coordinator, is the Point of Contact for scheduling site visits/tours. His phone numbers are – Cell Number 972 979 7667, Office Phone Number 972 292 6516. Sign in is required.

Contractors who do not visit/tour the sites with Wes prior to February 23, 2012 at 4:00PM will not be permitted to submit bids. Site visits/tours will be conducted from February 20, 2012 to February 23, 2012 from the hours of 8:00AM to 4:00PM CST.

Vendors who may have already submitted a bid and feel this addendum may change their bid price, may pick up their bid, and return it by the closing date. If picking up the bid is not feasible, any new bid submitted by your firm will supersede one previously submitted. Acknowledge receipt of this addendum by initialing in the appropriate space on the bid document.
Sincerely,

Jean Stelatella, CPIM, CPPB
Buyer
City of Frisco